

Decision No. R20-0773-E

**BEFORE THE PUBLIC UTILITIES COMMISSION OF THE STATE OF COLORADO**

PROCEEDING NO. 19R-0654E

---

IN THE MATTER OF THE PROPOSED AMENDMENTS TO RULES REGULATING  
ELECTRIC UTILITIES, 4 CODE OF COLORADO REGULATIONS 723-3, RELATING  
TO INTERCONNECTION PROCEDURES AND STANDARDS.

---

**ERRATA NOTICE FOR**  
**RECOMMENDED DECISION OF**  
**ADMINISTRATIVE LAW JUDGE**  
**STEVEN H. DENMAN**  
**AMENDING AND ADOPTING RULES**

---

---

Errata mailed November 13, 2020

Original Decision No. R20-0773 mailed November 5, 2020

1. The first sentence of Rule 3853(j) on page 35 of Attachment A (Redline Copy of the Rules) and page 12 of Attachment B (Clean Copy of the rules) of the amended rules reads as:

Commissioning tests of the IC's installed DER shall be performed pursuant to applicable codes and standards, including IEEE Standard 1547.1 "IEEE Standard Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems" (2005).

That sentence cites to the 2005 edition of IEEE Standard 1547.1. That is incorrect. The correct edition is 2020. The sentence shall be amended to read as follows:

Commissioning tests of the IC's installed DER shall be performed pursuant to applicable codes and standards, including IEEE Standard 1547.1 "IEEE Standard Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems" (2020).

2. The first sentence of Subparagraph 3855(b)(VII) on pages 46 and 47 of Attachment A (Redline Copy of the Rules) and page 23 of Attachment B (Clean Copy of the rules) of the amended rules reads as:

If the proposed interconnection resource is to be interconnected on single-phase shared secondary, the aggregate generation capacity on the shared secondary, including the proposed small generating facility, shall not exceed 205 kW AC.

That sentence states that the aggregate generation capacity shall not exceed 205 kW AC. That is incorrect. The correct aggregate generation capacity should be 25 kW AC. The sentence shall be amended to read as follows:

If the proposed interconnection resource is to be interconnected on single-phase shared secondary, the aggregate generation capacity on the shared secondary, including the proposed small generating facility, shall not exceed 25 kW AC.

3. In Rule 3857, which is the list of Certification Codes and Standards, on page 55 of Attachment A (Redline Copy of the Rules) and page 32 of Attachment B (Clean Copy of the rules) shows the “IEEE Standard Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems” as:

IEEE Std. 1547.1-2005, IEEE Standard Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems

The cite to the 2005 edition is incorrect. The correct edition is 2020. That entry shall be amended to read as follows:

IEEE Std. 1547.1-2020, IEEE Standard Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems

4. Amended copies of Attachments A and B are attached to this Errata Notice. There are no changes to the Recommended Decision in this matter.

(S E A L)



THE PUBLIC UTILITIES COMMISSION  
OF THE STATE OF COLORADO

STEVEN H. DENMAN

---

Administrative Law Judge

ATTEST: A TRUE COPY

A handwritten signature in cursive script that reads "Doug Dean".

Doug Dean,  
Director