

COLORADO DEPARTMENT OF REGULATORY AGENCIES

Public Utilities Commission

4 CODE OF COLORADO REGULATIONS (CCR) 723-3

PART 3 RULES REGULATING ELECTRIC UTILITIES

SMALL GENERATION INTERCONNECTION PROCEDURES AND STANDARDS.

3850. Applicability.

The following ~~small generator~~ interconnection procedures (~~SGIP~~) shall apply to all retail renewable distributed generation and other distributed energy small generation resources ~~including eligible renewable energy resources~~ connected to the utility. Each utility shall also provide, on its web site, interconnection standards or other technical guidance not included in these procedures. This rule largely tracks the 2013 FERC amended version of the FERC Order-2006 Small Generator Interconnection Procedures.

3851. Overview and Purpose.

Infrastructure security of electric system equipment and operations and control hardware and software is essential to ensure day-to-day reliability and operational security. The Commission expects all utilities, market participants, and Interconnection Customers interconnected with electric systems to comply with the recommendations offered by the President's Critical Infrastructure Protection Board and best practice recommendations from the electric reliability authority. All ~~public~~ utilities are expected to meet basic standards for electric system infrastructure and operational security, including physical, operational, and cyber-security practices.

The purpose of these rules is to establish reasonable interconnection and insurance requirements for retail renewable distributed generation and other distributed energy resources that connect to a utility's system.

3852. Definitions.

The following definitions apply only to rules ~~36653850 to 3858~~. ~~Defined terms used herein shall have the meanings specified in the paragraph (a) of this rule.~~

- (a) "Business day" means Monday through Friday, excluding Federal Holidays.
- (b) "Distributed energy resource" or "DER" "Small generating facility" means the interconnection customer's source of electric power, including retail renewable distributed generation, other small generation facilities device for the production of electricity, and energy storage systems, as identified in the interconnection request, but shall not include the interconnection facilities not owned by the interconnection customer. An interconnection system or a supplemental DER

device that is necessary for compliance with IEEE 1547 and is owned by the interconnection customer is part of a DER.

- (c) “Distribution system” means the utility’s facilities and equipment used to transmit electricity to ultimate usage points such as homes and industries directly from nearby ~~generators-DER~~ or from interchanges with higher voltage transmission networks which transport bulk power over longer distances. The voltage levels at which distribution systems operate differ among areas.
- (d) “Distribution upgrades” means the additions, modifications, and upgrades to the utility’s distribution system at or beyond the point of interconnection to facilitate interconnection of the ~~small-generating-facility-DER~~ and render the service necessary to effect the interconnection customer’s operation of ~~on-site-generation-DER~~. Distribution upgrades do not include interconnection facilities.
- (e) “Highly seasonal circuit” means a circuit with a ratio of annual peak load to off-season peak load greater than six.
- (f) “Interconnection agreement” means a legally binding contract between the interconnection customers and the utility that formally documents terms and conditions related to the operation and maintenance of any DER in accordance with the utility’s tariffs on file with the Commission.
- (g) “Interconnection customer” or “IC” means any entity, including the utility, any affiliates or subsidiaries of either, that proposes to interconnect its ~~small-generating-facility-DER~~ with the utility’s system.
- (h) “Interconnection facilities” means the utility’s interconnection facilities and the interconnection customer’s interconnection facilities. Collectively, interconnection facilities include all facilities and equipment between the ~~small-generating-facility-DER~~ and the point of interconnection, including any modification, additions or upgrades that are necessary to physically and electrically interconnect the ~~small-generating-facility-DER~~ to the utility’s system. Interconnection facilities are sole use facilities and shall not include distribution upgrades.
- (i) “Interconnection request” means the interconnection customer’s request, in accordance with any applicable utility tariff, to interconnect a new small generating facility, or to increase the capacity of, or make a material modification to the operating characteristics of, an existing ~~small-generating-facility-DER~~ that is interconnected with the utility’s system.
- (j) “Minimum daytime loading” means the lowest daily peak in the year on the line section.
- (k) “Minor modifications” means modifications to the utility’s distribution system or to the interconnection facilities that do have a material impact on the cost or on the timing of an interconnection request.
- (l) “Party” or “Parties” means the utility, interconnection customer, or any combination of the above.
- (m) “Point of interconnection” means the point where the Interconnection facilities connect with the utility’s system.

- (n) "Study process" means the procedure for evaluating an interconnection request that includes the Level 3 scoping meeting, feasibility study, system impact study, and facilities study.
- (o) "System" means the facilities owned, controlled, or operated by the utility that are used to provide electric service under the tariff.
- (p) "Upgrades" means the required additions and modifications to the utility's system at or beyond the point of interconnection. Upgrades do not include interconnection facilities.

3853. General Interconnection Procedures, General overview.

Applicability.

- (a) Pre-application procedures.
 - (I) Prior to submitting its interconnection request, the interconnection customer may ask the utility interconnection contact employee or office whether the proposed interconnection is subject to these procedures. The utility shall respond within 15 business days.
 - (II) The utility shall designate an employee or office from which information on the application process and on an affected system can be obtained through informal requests from the interconnection customer presenting a proposed project for a specific site. The name, telephone number, and e-mail address of such contact employee or office shall be made available on the utility's Internet web site.
 - (III) In response to an informal pre-application request, the utility shall provide ~~Electric~~-electric system information for specific locations, feeders, or small areas ~~shall be provided~~ to the interconnection customer ~~upon request~~ and may include relevant system studies, interconnection studies, and other materials useful to an understanding of an interconnection at a particular point on the utility's system, to the extent such provision does not violate confidentiality provisions of prior agreements or critical infrastructure requirements. The utility shall comply with reasonable requests for such information unless such information is proprietary or confidential and cannot be provided pursuant to a confidentiality agreement.
 - (IV) An interconnection customer may submit a formal written request for a pre-application report on a proposed interconnection at a specific site using a form supplied by the utility, unless such information is proprietary or confidential and cannot be provided pursuant to a confidentiality agreement. The utility may charge a fee for the pre-application report.
 - (A) The utility shall provide the pre-application report to the interconnection customer within 20 business days of receipt of the completed request form and payment of the fee.
 - (B) The pre-application report shall be non-binding on the utility and shall not confer any rights to the interconnection customer. The provided information shall not guarantee that an interconnection may be completed. Data provided in the pre-application report may become outdated at the time of the submission of the complete interconnection request.

- (C) The pre-application report need only include existing information. A pre-application report request does not obligate the utility to conduct a study or other analysis of the proposed DER in the event that data is not readily available.
- (D) If the utility cannot complete all or some of a pre- application report due to lack of available data, the utility nonetheless shall provide the interconnection customer with a pre- application report that includes the data that is available.
- (E) Notwithstanding any of the provisions of this section, the utility shall, in good faith, include data in the pre- application report that represents the best available information at the time of reporting. The pre- application report will include the following information:
 - (i) total capacity (in MW) of substation/area bus, bank or circuit based on normal or operating ratings likely to serve the proposed point of interconnection;
 - (ii) existing aggregate generation DER capacity (in MW) interconnected to a substation/area bus, bank or circuit (i.e., amount of DER online) likely to serve the proposed point of interconnection;
 - (iii) aggregate queued DER capacity (in MW) for a substation/area bus, bank or circuit (i.e., amount of DER in the queue) likely to serve the proposed point of interconnection;
 - (iv) available capacity (in MW) of substation/area bus or bank and circuit likely to serve the proposed point of interconnection (i.e., total capacity less the sum of existing aggregate DER capacity and aggregate queued DER capacity);
 - (v) substation nominal distribution voltage and/or transmission nominal voltage, if applicable;
 - (vi) nominal distribution circuit voltage at the proposed point of interconnection;
 - (vii) approximate circuit distance between the proposed point of interconnection and the substation;
 - (viii) relevant line section(s) actual or estimated peak load and minimum load data, including daytime minimum load as described in the supplemental review minimum load screen section (c)(III)(G)(i) and absolute minimum load at the time of DER production, when available;
 - (ix) number and rating of protective devices and number and type (standard, bi-directional) of voltage regulating devices between the proposed point of interconnection and the substation/area. Identify whether the substation has a load tap changer;

- (x) number of phases available at the proposed point of interconnection. If a single phase, distance from the three- phase circuit;
 - (xi) limiting conductor ratings from the proposed point of interconnection to the distribution substation;
 - (xii) whether the point of interconnection is located on a spot network, grid network, or radial supply; and.
 - (xiii) existing or known constraints such as, but not limited to, electrical dependencies at that location, short circuit interrupting capacity issues, power quality or stability issues on the circuit, capacity constraints, or secondary networks, based on the proposed point of interconnection,
- (b) Capacity of the small generating facility DER.
- (I) If the interconnection request is for an increase in capacity for an existing small generating facilityDER, the interconnection request shall be evaluated on the basis of the new total capacity of the small generating facilityDER.
 - (II) If the interconnection request is for a small generating facilityDER that includes multiple energy production devicescomponents at a site for which the interconnection customer seeks a single point of interconnection, the interconnection request shall be evaluated on the basis of the aggregate capacity of the multiple devicescomponents.
 - (III) The interconnection request shall be evaluated using the maximum rated capacity of the small generating facilityDER. At the utility's discretion, the interconnection request may be evaluated using less than the maximum rated capacity of the DER if the utility determines that the DER is only capable of injecting less power into the utility's system.
- (c) Interconnection requests.
- (I) The interconnection customer shall submit its interconnection request to the utility, together with the processing fee or deposit specified in the interconnection request. A single request to interconnect may be submitted by the interconnection customer for DER that combines small generation facilities for the production of electricity and energy storage systems. Such DER may be subject to one interconnection agreement.
 - (II) The interconnection request shall be date- and time-stamped upon receipt. The original date- and time-stamp applied to the interconnection request at the time of its original submission shall be accepted as the qualifying date- and time-stamp for the purposes of any timetable in these procedures.
 - (III) The interconnection customer shall be notified of receipt by the utility within three business days of receiving the interconnection request which notification may be to an e-mail address or fax number provided by IC.

- (IV) The utility shall notify the interconnection customer within ten business days of the receipt of the interconnection request as to whether the interconnection request is complete or incomplete. If the interconnection request is incomplete, the utility shall provide, along with the notice that the interconnection request is incomplete, a written list detailing all information that must be provided to complete the interconnection request. The interconnection customer will have ten business days after receipt of the notice to submit the listed information or to request an extension of time to provide such information. If the IC does not provide the listed information or a request for an extension of time within the deadline, the interconnection request will be deemed withdrawn.
- (V) An interconnection request will be deemed complete upon submission of the listed information to the utility.
- (VI) ~~Modification of the interconnection request.~~ Any modification to ~~machine-DER~~ data or equipment configuration or to the interconnection site of the ~~small-generating facility~~DER that has a material impact on the cost or timing of the interconnection request ~~not agreed to in writing by the utility and the IC~~ may be deemed a withdrawal of the interconnection request and may require submission of a new interconnection request, ~~unless proper notification of each party by the other and a reasonable time to cure the problems created by the changes are undertaken.~~ A new interconnection request shall not be required for minor modifications to DER data or equipment configuration or to the interconnection site of the DER.
- (VII) ~~Site control.~~ Documentation of site control must be submitted with the interconnection request. Site control may be demonstrated through:
- (A) ownership of, a leasehold interest in, or a right to develop a site for the purpose of constructing the ~~small-generating facility~~DER;
 - (B) an option to purchase or acquire a leasehold site for such purpose; or
 - (C) an exclusivity or other business relationship between the IC and the entity having the right to sell, lease, or grant the IC the right to possess or occupy a site for such purpose.
- (VIII) ~~Queue position.~~ The utility shall place interconnection requests in a first come, first served order per feeder, per substation transfer, and per substation based upon the date- and time-stamp of the interconnection request. The order of each interconnection request will be used to determine the cost responsibility for the upgrades necessary to accommodate the interconnection. At the utility's option, interconnection requests may be studied serially or in clusters for the purpose of the system impact study.
- (d) Evaluation of interconnection requests.
- (I) A request to interconnect ~~a certified inverter-based small-generating facility~~DER no larger than ten kW shall be evaluated under the Level 1 Process.

- (II) A request to interconnect ~~a certified small generating facility~~DER no larger than two MW shall be evaluated under the Level 2 Process (Fast Track) in accordance with the eligibility requirements in paragraph 3855(a).
 - (III) A request to interconnect ~~a small generating facility larger than two MW but no larger than ten MW or a small generating facility~~DER that does not pass the Level 1 or Level 2 Process, shall be evaluated under the Level 3 Process.
- (e) Interconnection agreements.
- (I) Any DER operating in parallel with the utility's system is required to have an interconnection agreement with the utility to ensure safety, system reliability, and operational compatibility. DER is considered to be operating in parallel with the utility's system when it is connected to the utility's system and can supply electricity to the interconnection customer simultaneously with the utility's supply of electricity. References in these procedures to interconnection agreement are to the ~~Small Generator Interconnection Agreement (SGIA)~~utility's interconnection agreement as provided on its web site.
 - (II) ~~Assignment/Transfer of ownership of the facility.~~—Interconnection agreements shall survive transfer of ownership of the ~~generating facility~~DER to a new owner when the new owner agrees in writing to comply with the terms of the agreement and so notifies the utility.
 - (III) ~~Interconnection agreement.~~—After receiving an interconnection agreement from the utility, the IC shall have 30 business days or another mutually agreeable time-frame to sign and return the interconnection agreement, or request that the utility file an unexecuted interconnection agreement with the Commission. If the IC does not sign the interconnection agreement, or ask that it be filed unexecuted by the utility within 30 business days, the interconnection request shall be deemed withdrawn. The utility shall provide the IC a fully executed interconnection agreement within two business days after receiving a signed interconnection agreement from the IC. After the interconnection agreement is signed by the parties, the interconnection of the ~~small generating facility~~DER shall proceed under the provisions of the interconnection agreement.
 - (IV) Once the DER has been authorized by the utility to commence operation in parallel with the utility system, the interconnection customer shall abide by all rules and procedures pertaining to parallel operation in the utility's tariffs and in the interconnection agreement.
 - (V) The interconnection customer shall be responsible for the utility's reasonable and necessary cost for the purchase, installation, operation, maintenance, testing, repair and replacement of utility upgrades or utility interconnection facilities not required to serve other utility customers. Such upgrades or facilities shall be specified in the interconnection agreement unless otherwise covered by the utility's tariff or excluded by interconnection agreement.
- (f) Reasonable efforts. The utility shall make reasonable efforts to meet all time frames provided in these procedures unless the utility and the IC agree to a different schedule. If the utility cannot meet a deadline provided herein, it shall notify the IC explain the reason for the failure to meet the

deadline, and provide an estimated time by which it will complete the applicable interconnection procedure in the process.

- (g) Disputes.
- (I) The parties agree to attempt to resolve all disputes arising out of the interconnection process according to the provisions of this article.
 - (II) In the event of a dispute, either party shall provide the other party with a written notice of dispute. Such notice shall describe in detail the nature of the dispute. If the dispute has not been resolved within five business days after receipt of the notice, either party may contact a mutually agreed upon third party dispute resolution service for assistance in resolving the dispute.
 - (III) The dispute resolution service will assist the parties in either resolving their dispute or in selecting an appropriate dispute resolution venue (e.g., mediation, settlement judge, early neutral evaluation, or technical expert) to assist the parties in resolving their dispute.
 - (IV) Each party agrees to conduct all negotiations in good faith and will be responsible for one-half of any costs paid to neutral third-parties.
 - (V) If neither party elects to seek assistance from the dispute resolution service, or if the attempted dispute resolution fails, then either party may exercise whatever rights and remedies it may have in equity or law consistent with the terms of the agreements between the parties or it may seek resolution at the Commission.
- (h) Interconnection metering. Except as otherwise required by ~~rule 3664~~ the Commission's Net Metering Rules or by the terms of a Commission-approved program offered by the utility for the purpose of encouraging the development of cost effective retail renewable distributed generation, any metering necessitated by the use of the ~~small generating facility-DER~~ shall be installed at the IC's expense in accordance with Commission requirements or the utility's specifications.
- (i) Commissioning tests. Commissioning tests of the IC's installed ~~equipment-DER~~ shall be performed pursuant to applicable codes and standards, including IEEE1547.1-~~2005~~ "IEEE Standard Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems". The utility must be given at least five business days written notice, or as otherwise mutually agreed to by the parties, of the tests and may be present to witness the commissioning tests. The utility shall be compensated by the IC for its expense in witnessing level 2 and Level 3 commissioning tests. The utility shall provide to the IC an operational approval letter within three business days after notification that the commissioning test has been successfully completed. Such letter may be provided via e-mail.
- (j) Confidentiality.
- (I) Confidential information shall mean any confidential and/or proprietary information provided by one party to the other party that is clearly marked or otherwise designated "Confidential." All design, operating specifications, and metering data provided by the IC shall be deemed confidential information regardless of whether it is clearly marked or otherwise designated as such.

- (II) Confidential information does not include information previously in the public domain, required to be publicly submitted or divulged by governmental authorities (after notice to the other party and after exhausting any opportunity to oppose such publication or release), or necessary to be divulged in an action to enforce an agreement between the parties. Each party receiving confidential information shall hold such information in confidence and shall not disclose it to any third party nor to the public without the prior written authorization from the party providing that information, except to fulfill obligations under agreements between the parties, or to fulfill legal or regulatory requirements.
- (A) Each party shall employ at least the same standard of care to protect confidential information obtained from the other party as it employs to protect its own confidential information.
- (B) Each party is entitled to equitable relief, by injunction or otherwise, to enforce its rights under this provision to prevent the release of confidential information without bond or proof of damages, and may seek other remedies available at law or in equity for breach of this provision.
- (III) Notwithstanding anything in this article to the contrary, if the Commission, during the course of an investigation or otherwise, requests information from one of the parties that is otherwise required to be maintained in confidence, the party shall provide the requested information to the Commission, within the time provided for in the request for information. In providing the information to the Commission, the party may request that the information be treated as confidential and non-public by the Commission and that the information be withheld from public disclosure. Parties are prohibited from notifying the other party prior to the release of the confidential information to the Commission. The party shall notify the other party when it is notified by the Commission that a request to release confidential information has been received by the Commission, at which time either of the parties may respond before such information would be made public.
- (k) Comparability. The utility shall receive, process, and analyze all interconnection requests in a timely manner as set forth in this ~~document~~rule. The utility shall use the same reasonable efforts in processing and analyzing interconnection requests from all interconnection customers, whether the ~~small generating facility-DER~~ is owned or operated by the utility, its subsidiaries or affiliates, or others.
- (l) Record retention. The utility shall maintain for three years records, subject to audit, of all interconnection requests received under these procedures, the times required to complete interconnection request approvals and disapprovals, and justification for the actions taken on the interconnection requests.
- (m) Coordination with affected systems. The utility shall coordinate the conduct of any studies required to determine the impact of the interconnection request on affected systems with affected system operators and, if possible, include those results (if available) in its applicable interconnection study within the time frame specified in ~~these procedures~~this rule. The utility will include such affected system operators in all meetings held with the IC as required by ~~these procedures~~this rule. The IC will cooperate with the utility in all matters related to the conduct of studies and the determination of modifications to affected systems. A utility which may be an affected system shall cooperate with the utility with which interconnection has been requested in

all matters related to the conduct of studies and the determination of modifications to affected systems.

(n) Insurance.

- (I) For systems of ten kW or less, the customer, at its own expense, shall secure and maintain in effect during the term of the interconnection agreement liability insurance with a combined single limit for bodily injury and property damage of not less than \$300,000 for each occurrence. For ~~systems-DER~~ above ten kW and up to 500 kW, customer, at its own expense, shall secure and maintain in effect during the term of the interconnection agreement liability insurance with a combined single limit for bodily injury and property damage of not less than \$1,000,000 for each occurrence. For ~~systems-DER~~ above 500 kW and up to two MW, customer, at its own expense, shall secure and maintain in effect during the term of the interconnection agreement liability insurance with a combined single limit for bodily injury and property damage of not less than \$2,000,000 for each occurrence. Insurance coverage for ~~systems-DER~~ greater than two MW shall be determined on a case-by-case basis by the utility and shall reflect the size of the installation and the potential for system damage.
- (II) For ~~systems-DER~~ over 500 kW, the utility shall be named as an additional insured by endorsement to the insurance policy and the policy shall provide that written notice be given to the utility at least 30 days prior to any cancellation or reduction of any coverage. Such liability insurance shall provide, by endorsement to the policy, that the utility shall not by reason of its inclusion as an additional insured incur liability to the insurance carrier for the payment of premium of such insurance. For all ~~solar-systemsDER~~, the liability insurance shall not exclude coverage for any incident related to the subject ~~generator-DER~~ or its operation.
- (III) Certificates of Insurance evidencing the requisite coverage and provision(s) shall be furnished to utility prior to the date of interconnection of the generation-systemDER. Utilities shall be permitted to periodically obtain proof of current insurance coverage from the generating-interconnection customer in order to verify proper liability insurance coverage. Customer will not be allowed to commence or continue interconnected operations unless evidence is provided that satisfactory insurance coverage is in effect at all times.

3854. Level 1 Process (10 kW Inverter Process).

~~The~~ This rule establishes the procedures for evaluating an interconnection request for a certified inverter-based ~~small-generating-facility-DER~~ no larger than ten kW. The application process uses an all-in-one document (Application) that includes a simplified ~~Interconnection-interconnection Requestrequest~~, simplified procedures, and a brief set of terms and conditions.

(a) General Level 1 procedures.

- (I) The ~~interconnection-customer-(customer)IC~~ completes ~~the interconnection request~~ (Applicationapplication) and submits it to the utility.

- (II) The utility acknowledges to the customer receipt of the application within three business days of receipt.
- (III) The utility evaluates the application for completeness and notifies the customer within ten business days of receipt that the application is or is not complete and, if not, advises what material is missing.
- (IV) Within 15 days, the utility shall ~~conduct an initial review, which shall include the following screening criteria: verify whether the DER can be interconnected safely and reliably using the same screens as applied in Level 2 process as set forth in rule 3855. If the interconnection fails these screens, the utility shall consider this a failure of the Level 2 process screens in rule 3855. The utility shall continue the interconnection review under the Level 2 process, starting at paragraph 3855(c), provided that the IC pays the difference in the Level 2 process application fee and deposit requirements. The utility may perform supplemental reviews within the 15 day period to address highly seasonal circuits. For interconnection of a proposed small generating facility to a radial distribution circuit, the aggregated generation, including the proposed small generating facility, on the line section shall not exceed 15 percent of the line section annual peak load as most recently measured at the substation or calculated for the line section. For highly seasonal circuits only, the aggregate generation, including the proposed small generation facility, on the line section shall not exceed 15 percent of two times the minimum daytime loading. A line section is that portion of a utility's electric system connected to a customer bounded by automatic sectionalizing devices or the end of the distribution line. A fuse is not an automatic sectionalizing device.~~
- ~~If the proposed small generating facility is to be interconnected on single phase shared secondary, the aggregate generation capacity on the shared secondary, including the proposed small generating facility, shall not exceed 20 kW.~~
- ~~If the proposed small generating facility is single phase and is to be interconnected on a center tap neutral of a 240 volt service, its addition shall not create an imbalance between the two sides of the 240 volt service of more than 20 percent of the nameplate rating of the service transformer.~~
- ~~No construction of facilities by the utility on its own system shall be required to accommodate the small generating facility.~~
- (V) Provided all the criteria ~~in paragraph (g)~~ of this rule ~~3854~~ are met, unless the utility determines and demonstrates that the ~~small generating facility-DER~~ cannot be interconnected safely and reliably, the utility approves and executes the application and returns it to the customer.
- (VI) After installation, the customer returns the certificate of completion to the utility. Prior to parallel operation, the utility may inspect the ~~small generating facility-DER~~ for compliance with standards, which may include a witness test, and may schedule appropriate metering replacement, if necessary.
- (VII) The utility ~~shall notify~~ notifies the customer ~~in writing or by fax or e-mail~~ that interconnection of the ~~small generating facility-DER~~ is authorized within five business

days. If the witness test is not satisfactory, the utility has the right to disconnect the ~~small generating facility~~DER. The customer has no right to operate in parallel until a witness test has been performed, or previously waived on the ~~application~~Application. The utility is obligated to complete this witness test within ten business days of the receipt of the certificate of completion.

(b) Level 1 ~~10 kW Inverter Process~~application. ~~The following constitutes an application for interconnecting a certified inverter-based small generating facility no larger than ten KW. Application for Interconnecting a Certified Inverter-Based Small Generating Facility No Larger than 10kW~~

(I) ~~Contact information.~~The customer must provide in the application the contact information for the legal applicant (i.e., the interconnection customer). If another entity is responsible for interfacing with the utility, that contact information must be provided on the application.

(II) ~~This The Application~~application is considered complete when it provides all applicable and correct information as required below. Additional information to evaluate the application may be required.

(III) The application shall state the following:

Processing fee:

A fee of _____ must accompany this application.

Interconnection customer:

Name:

Contact Person:

Address:

City: State: Zip:

Telephone (Day): (Evening):

Fax: E-Mail Address:

Engineering firm or installer (If applicable):

Contact Person:

Address:

City: State: Zip:

Telephone:

Fax: E-Mail Address:

Contact (if different from Interconnection ~~e~~Customer):

Name:

Address:

City: State: Zip:

Telephone (Day): (Evening):

Fax: E-Mail Address:

Owner of the facility (include percent ownership by any electric utility):

~~Small generating facility~~ DER information:

Location (if different from above):

~~Electric service company~~ Utility:

Account number:

~~Small generator ten kW inverter process~~ DER components:

Inverter manufacturer: _____ Model

Nameplate rating: (kW) (kVA) (AC Volts)

Single phase _____ Three phase _____

System design capacity: _____ (kW) _____ (kVA)

Prime mover: Photovoltaic Reciprocating Engine Fuel Cell Turbine Other

Energy source: Solar Wind Hydro Diesel Natural Gas Fuel Oil Other (describe)

Is the equipment UL1741 Listed? Yes _____ No _____

If Yes, attach manufacturer's cut-sheet showing UL1741 listing.

Estimated installation date: _____ Estimated in-service date: _____

The ten kW inverter process is available only for inverter-based ~~small generating facilities~~ DER no larger than ten kW that meet the codes, standards, and certification requirements of paragraphs (h) and (i) of this rule, or the ~~QRU~~ utility has reviewed the design or tested the proposed ~~small generating facility~~ DER and is satisfied that it is safe to operate.

List components of the small generating facility equipment package that are currently certified:

Equipment type certifying entity:

- 1.
- 2.
- 3.
- 4.
- 5.

Interconnection customer signature: _____

I hereby certify that, to the best of my knowledge, the information provided in this Application is true. I agree to abide by the Terms and Conditions for Interconnecting an Inverter-Based ~~Small Generating Facility~~DER No Larger than 10kW and return the Certificate of Completion when the ~~Small Generating Facility~~DER has been installed.

Signed: _____

Title:

Date:

Contingent approval to interconnect the small generating facility.

(For company use only)

Interconnection of the small generating facility is approved contingent upon the terms and conditions for interconnecting an inverter-based small generating facility no larger than ten kW and return of the certificate of completion.

Company signature: _____

Title: Date:

Application ID number: _____

Company waives inspection/witness test? Yes ____ No ____

(c) Level 1 Terms and conditions ~~for Level 1 interconnections — small generating facility no larger than ten kW.~~

(l) Construction of the facility. The interconnection customer may proceed to construct the ~~small generating facility~~DER when the utility approves the interconnection request (the application) and returns it to the IC.

- (II) Interconnection and operation. The IC may operate ~~small generating facility~~ the DER and interconnect with the utility's electric system once all of the following have occurred:
- (A) upon completing construction, the interconnection customer will cause the ~~small generating facility~~ DER to be inspected or otherwise certified by the appropriate local electrical wiring inspector with jurisdiction;
 - (B) the customer returns the certificate of completion to the utility; and
 - (C) the utility has completed its inspection of the ~~small generating facility~~ DER. All inspections must be conducted by the utility, at its own expense, within ten business days after receipt of the certificate of completion and shall take place at a time agreeable to the parties. The utility shall provide a written statement that the ~~small generating facility~~ DER has passed inspection or shall notify the customer of what steps it must take to pass inspection as soon as practicable after the inspection takes place.
 - (D) The utility has the right to disconnect the ~~small generating facility~~ DER in the event of improper installation or failure to return the certificate of completion.
- (III) Safe operations and maintenance. The interconnection customer shall be fully responsible to operate, maintain, and repair the ~~small generating facility~~ DER as required to ensure that it complies at all times with the interconnection standards to which it has been certified.
- (IV) Access. The utility shall have access to the disconnect switch and metering equipment of the ~~small generating facility~~ DER at all times. The utility shall provide reasonable notice to the customer when possible prior to using its right of access.
- (V) Disconnection. The utility may temporarily disconnect the ~~small generating facility~~ DER as allowed in the interconnection agreement and upon the following conditions:
- (A) for scheduled outages per notice requirements in the utility's tariff or Commission rules;
 - (B) for unscheduled outages or emergency conditions pursuant to the utility's tariff or Commission rules; or
 - (C) if the ~~small generating facility~~ DER does not operate in the manner consistent with these terms and conditions.
 - (D) The utility shall inform the interconnection customer in advance of any scheduled disconnection, or as is reasonable after an unscheduled disconnection.
- (VI) Indemnification. The parties shall at all times indemnify, defend, and save the other party harmless from, any and all damages, losses, claims, including claims and actions relating to injury to or death of any person or damage to property, demand, suits, recoveries, costs and expenses, court costs, attorney fees, and all other obligations by or to third parties, arising out of or resulting from the other party's action or inactions of its

obligations under this agreement on behalf of the indemnifying party, except in cases of gross negligence or intentional wrongdoing by the indemnified party.

- (VII) Insurance. The interconnection customer, at its own expense, shall secure and maintain in effect during the term of this agreement, liability insurance with a combined single limit for bodily injury and property damage of not less than \$300,000 each occurrence. Such liability insurance shall not exclude coverage for any incident related to the ~~subject generator-DER~~ or its operation. ~~The utility shall be named as an additional insured under the liability policy unless the system is a solar system installed on a premise using the residential tariff and has a design capacity of ten kW or less.~~ The policy shall include that written notice be given to the utility at least 30 days prior to any cancellation or reduction of any coverage. A copy of the liability insurance certificate must be received by the utility prior to ~~plant-DER~~ operation. Certificates of insurance evidencing the requisite coverage and provision(s) shall be furnished to utility prior to date of interconnection of the ~~generation-system-DER~~. Utilities shall be permitted to periodically obtain proof of current insurance coverage from the ~~generating-interconnection~~ customer in order to verify proper liability insurance coverage. The interconnection customer will not be allowed to commence or continue interconnected operations unless evidence is provided that satisfactory insurance coverage is in effect at all times.
- (VIII) Limitation of liability. Each party's liability to the other party for any loss, cost, claim, injury, liability, or expense, including reasonable attorney's fees, relating to or arising from any act or omission in its performance of ~~this-the interconnection~~ agreement, shall be limited to the amount of direct damage actually incurred. In no event shall either party be liable to the other party for any indirect, incidental, special, consequential, or punitive damages of any kind whatsoever, except as allowed under subparagraph (~~ic~~)(VI) of this rule.
- (IX) Termination. The ~~interconnection~~ agreement to operate in parallel may be terminated under the following conditions.
- (A) By the customer by providing written notice to the utility.
 - (B) By the utility if the ~~small-generating-facility-DER~~ fails to operate for any consecutive 12 month period or the customer fails to remedy a violation of these terms and conditions.
 - (C) Permanent disconnection. In the event ~~this-the interconnection~~ agreement is terminated, the utility shall have the right to disconnect its facilities or direct the customer to disconnect its ~~small-generating-facility-DER~~.
 - (D) Survival rights. ~~This-The interconnection~~ agreement shall continue in effect after termination to the extent necessary to allow or require either party to fulfill rights or obligations that arose under the agreement.
- (X) Assignment/Transfer of ownership of the facility. ~~This-The interconnection~~ agreement shall survive the transfer of ownership of the small generating facility to a new owner when the new owner agrees in writing to comply with the terms of ~~this-the~~ agreement and so notifies the utility.

3855. Level 2 Process (Fast Track).

~~Applicability. The~~This fast track process is available to an IC proposing to interconnect its ~~small generating facility-DER~~ with the utility's system if the ~~small generating facility-DER is no larger than two MW and if the IC's proposed small generating facility meets the codes, standards, and certification requirements of Attachments 3 and 4 of these procedures~~ the eligibility provisions in this rule 3855.

(a) Eligibility.

- (I) Eligibility for the Level 2 Process is determined based upon the type and size of the DER as well as the voltage of the utility line and the location of and the type of utility line at the point of interconnection. An interconnection customer may determine whether the DER is eligible for the Level 2 Process by requesting a pre-application report pursuant to subparagraph 3853(a)(IV).
- (II) For certified inverter-based systems, the size limit of the DER varies according to the voltage of the utility line at the proposed point of interconnection. Certified inverter-based DER facilities located within 2.5 electrical circuit miles of a substation and on a mainline are eligible for the Level 2 Process under the higher thresholds pursuant to this rule 3856.

<u>Level 2 Process Eligibility for Inverter-Based Systems</u>		
<u>Line Voltage</u>	<u>Eligibility Regardless of Location</u>	<u>Eligibility Meeting Location Requirements (Mainline and Substation)</u>
<u>< 5 kV</u>	<u>≤ 500 kW</u>	<u>≤ 500 kW</u>
<u>≥ 5 kV and < 15 kV</u>	<u>≤ 2 MW</u>	<u>≤ 3 MW</u>
<u>≥ 5 kV and < 30 kV</u>	<u>≤ 3 MW</u>	<u>≤ 4 MW</u>
<u>≥ 30 kV and < 69 kV</u>	<u>≤ 4 MW</u>	<u>≤ 5 MW</u>

(III) All synchronous and induction facilities must be no larger than 2 MW to be eligible for the Level 2 process, regardless of location.

(IV) In addition to the size threshold, the DER must meet the codes, standards, and certification requirements of the Commission's Interconnection Procedures and Standards.

(b) Initial Review. Within 15 business days after the utility notifies the interconnection customer it has received a complete interconnection request, the utility shall perform an initial review using the screens set forth below, shall notify the interconnection customer of the results, and include with the notification copies of the analysis and data underlying the utility's determinations under the following screens:

(A) Screens.

(i) The proposed small generating facility's DER's point of interconnection must be on a portion of the utility's distribution system that is subject to the utility's tariffs. Proposed DER on highly seasonal circuits shall also be subject to the supplemental review pursuant to paragraph 3855(d).

- (II) For interconnection of a proposed ~~small generating facility~~DER to a radial distribution circuit, the aggregated generation, including the proposed ~~small generating facility~~DER, on the line section(s) shall not exceed 15 percent of the line section's annual peak load as most recently measured at the substation or calculated for the line section(s). ~~For highly seasonal circuits only, the aggregate generation, including the proposed small generation facility, on the line section shall not exceed 15 percent of two times the minimum daytime loading.~~—A line section is that portion of a utility's electric system connected to a customer bounded by automatic sectionalizing devices or the end of the distribution line. A fuse is not an automatic sectionalizing device.
- (III) The proposed ~~small generating facility~~DER, in aggregation with other generation on the distribution circuit, shall not contribute more than ten percent to the distribution circuit's maximum fault current at the point on the distribution feeder voltage (primary) level nearest the proposed point of change of ownership.
- (IV) The proposed ~~small generating facility~~DER, in aggregate with other ~~generation~~DER on the distribution circuit, shall not cause any distribution protective devices and equipment (including, but not limited to, substation breakers, fuse cutouts, and line reclosers), or interconnection customer equipment on the system to exceed 87.5 percent of the short circuit interrupting capability; nor shall the interconnection be proposed for a circuit that already exceeds 87.5 percent of the short circuit interrupting capability.
- (V) The proposed ~~small generating facility~~DER shall ~~have a starting voltage dip less than five percent and~~ meet the ~~rapid voltage charge and~~ flicker requirements of IEEE 519, 1992 version 1453 and IEEE 1457 based on the ~~appropriate test~~. ~~To meet this screen, the proposed generating facility must conform to the following two tests:~~

~~For starting voltage dip, the utility has two options for determining whether starting voltage dip is acceptable. The option to be used is at the utility's discretion.~~

~~Option 1: The utility may determine that the proposed generating facility's starting in-rush current is equal to or less than the continuous ampere rating of the Interconnection Customer's service equipment.~~

~~Option 2: The utility may determine the impedances of the service distribution transformer (if present) and the secondary conductors to the Interconnection Customer's service equipment and perform a voltage dip calculation. Alternatively, the utility may use tables or nomographs to determine the voltage dip. Voltage dips caused by starting the proposed generation facility must be less than five percent when measured at the primary side (high side) of a dedicated distribution transformer serving the proposed generating facility, for primary interconnections. The five percent voltage dip limit applies to the distribution transformer low side if the low side is shared with other customers and to the high side if the transformer is dedicated to the Interconnection Customer.~~

~~The second test is conformance with the relationship between voltage fluctuation and starting frequency presented in the table for flicker requirements in IEEE 519, 1992 version.~~

- (VI) ~~Using the table below, determine the~~ The type of interconnection to a primary distribution line ~~shall be determined based on the table below, including.~~ ~~This screen includes~~ a review of the type of electrical service provided to the ~~interconnection customer,~~ ~~including~~ line configuration, and the transformer connection to limit the potential for creating over-voltages on the utility's electric power system due to a loss of ground during the operating time of any anti-islanding function.

Primary Distribution Line Type	Type of Interconnection to Primary Distribution Line	Result/Criteria
Three-phase, three wire	3-phase or single phase, phase-to-phase	Pass screen
Three-phase, four wire	Effectively-grounded 3 phase or Single-phase, line-to-neutral	Pass screen

- (VII) If the proposed ~~small generating facility~~DER is to be interconnected on single-phase shared secondary, the aggregate generation capacity on the shared secondary, including the proposed small generating facility, shall not exceed 20 kW.
- (VIII) If the proposed ~~small generating facility~~DER is single-phase and is to be interconnected on a center tap neutral of a 240 volt service, its addition shall not create an imbalance between the two sides of the 240 volt service of more than 20 percent of the nameplate rating of the service transformer.
- (IX) No construction of facilities by the utility on its own system shall be required to accommodate the small generating facility.
- (X) ~~Interconnections to distribution networks.~~ For interconnection of a proposed ~~small generating facility~~DER to the load side of spot network protectors serving more than a single customer, the proposed ~~small generating facility~~DER must utilize an inverter-based equipment package and, together with the aggregated other inverter-based ~~generation~~DER, shall not exceed the smaller of five percent of a spot network's maximum load or 300 kW. For spot networks serving a single customer, the ~~small generator facility~~DER must use inverter-based equipment package and either meet the requirements above or shall use a protection scheme or operate the generator so as not to exceed on-site load or otherwise prevent nuisance operation of the spot network protectors.
- (XI) For interconnection of a proposed ~~small generating facility~~DER to the load side of area network protectors, the proposed ~~small generating facility~~DER must utilize an inverter-based equipment package and, together with the aggregated other inverter-based ~~generation~~DER, shall not exceed the smaller of ten percent of an area network's minimum load or 500 kW.

~~Notwithstanding sub-sections (1) or (2) above, each utility may incorporate into its interconnection standards, any change in interconnection guidelines related to networks pursuant to standards developed under IEEE 1547 for interconnections to networks. To the extent the new IEEE standards conflict with these existing guidelines, the new standards shall apply. In addition, and with the consent of the utility, a small generator facility may be interconnected to a spot or area network provided the facility uses a protection scheme that will prevent any power export from the customer's site including inadvertent export under fault conditions or otherwise prevent nuisance operation of the network protectors.~~

- (c) Customer options meeting.
- (I) If the proposed interconnection fails the screens, but the utility does not or cannot determine from the initial review that the ~~small generating facility~~DER may nevertheless be interconnected consistent with safety, reliability, and power quality standards unless the IC is willing to consider minor modifications or further study, the utility shall provide the IC with the opportunity to attend a customer options meeting.
 - (II) If the utility determines the interconnection request cannot be approved without minor modifications at minimal cost; ~~or without~~ a supplemental study or other additional studies or actions; or ~~at without~~ significant costs to address safety, reliability, or power quality problems, ~~within the five business day period after the determination,~~ the utility shall notify the IC within the five business day period after the determination and provide the data and analyses underlying its conclusion. Within ten business days of the utility's determination, the utility shall offer to convene a customer options meeting with the utility to review possible IC facility modifications or the screen analysis and related results, to determine what further steps are needed to permit the small generating facility to be connected safely and reliably. At the time of notification of the utility's determination, or at the customer options meeting, the utility shall:
 - (A) offer to perform facility modifications or minor modifications to the utility's electric system (e.g., changing meters, fuses, relay settings) and provide a non-binding good faith estimate of the limited cost to make such modifications to the utility's electric system;
 - (B) offer to perform a supplemental review ~~pursuant to paragraph 3855(d) if the utility concludes that the supplemental review might determine that the small generating facility could continue to qualify for interconnection pursuant to the fast track process,~~ and provide a non-binding good faith estimate of the costs and time of such review; or
 - (C) obtain the interconnection customer's agreement to continue evaluating the interconnection request under the Level 3 Study Process.
- (d) Supplemental ~~Review~~review.

- (I) ~~If the interconnection customer agrees to~~ To accept a utility's offer to conduct a supplemental review, the interconnection customer, within 15 business days of the offer, shall agree in writing to the supplemental review within 15 business days of the offer, and submit a deposit for the estimated costs provided in subsection (c)(III)(A)(ii) of this rule. If the written agreement and deposit have not been received by the utility within the 15 days, the interconnection request shall continue to be evaluated under the Level 3 Process, unless the request is withdrawn by the IC. The IC shall be responsible for the utility's actual costs for conducting the supplemental review. The IC must pay any review costs that exceed the deposit within 20 business days of receipt of the invoice or resolution of any dispute. If the deposit exceeds the invoiced costs, the utility will return such excess within 20 business days of the invoice without interest.
- (II) Within ~~ten~~ 30 business days following receipt of the deposit for a supplemental review, the utility will ~~determine if the Small Generating Facility can be interconnected safely and reliably perform a supplemental review of the proposed DER using the screens set forth below, notify the interconnection customers of the results of the screens in writing, and include with the notification copies of the analysis and data underlying the utility's determinations.~~
- (III) The interconnection customer may specify the order in which the utility completes the supplemental review screens.
- (IV) The utility shall notify the interconnection customer of the failure of the DER in any supplemental review screen or of the utility's inability to perform any screen for the DER. Within two business days of the receipt of such notice, the interconnection customer may grant the utility permission:
 - (A) to continue evaluating the proposed interconnection under this paragraph 3855(d);
 - (B) to continue evaluating the proposed interconnection under this subparagraph 3855(d) subject to the utility's determination of minor modifications;
 - (C) to terminate the supplemental review and instead to continue evaluating the DER under the Level 3 Process; or
 - (D) to terminate the supplemental review upon withdrawal of the interconnection request by the interconnection customer.
- (V) Minimum load, minimum loading, and minimum load data shall be specific to time(s) that the DER exports active power to the utility.
- (VI) Supplemental review screens.
 - (A) Minimum load screen.
 - (i) The DER capacity on the line section(s) shall be less than 100 percent of the minimum load for all line sections bounded by automatic sectionalizing devices upstream of the proposed DER.

- (ii) This screen shall be determined using 12 months of line section(s) minimum load data (including onsite load but not station service load served by the proposed DER), calculated minimum load data, or estimated minimum load data using existing data a power flow model. If minimum load data is not available or the minimum load data cannot be calculated estimated, the utility shall include the reason(s) that it is unable to calculate, estimate or determine minimum load in its supplemental review results notification under subparagraph 3855(d)(IV).
- (iii) The type of DER shall be taken into account when calculating or estimating circuit or line section(s) minimum load. The utility shall use daytime minimum load for solar photovoltaic (PV) DER with no battery storage (i.e., 10 a.m. to 4 p.m. for fixed panel systems and 8 a.m. to 6 p.m. for PV systems utilizing tracking systems). The utility shall use absolute minimum load for all other types of DER.
- (iv) Only the net injection into the utility's electric system shall be considered as part of the DER when this screen is applied to DER serving some station service load.
- (v) The utility shall not consider as part of the DER the capacity known to be already reflected in the minimum load data.

~~If so, the utility shall forward an executable interconnection agreement to the IC within five business days.~~

~~If so, and IC facility modifications are required to allow the small generating facility to be interconnected consistent with safety, reliability, and power quality standards under these procedures, the utility shall forward an executable interconnection agreement to the IC within five business days after confirmation that the interconnection customer has agreed to make the necessary changes at the interconnection customer's cost.~~

~~If so, and minor modifications to the utility's electric system are required to allow the small generating facility to be interconnected consistent with safety, reliability, and power quality standards under the Level 2 Fast Track Process, the utility shall forward an executable interconnection agreement to the IC within ten business days that requires the IC to pay the costs of such system modifications prior to interconnection.~~

~~If not, the interconnection request will continue to be evaluated under the Level 3 Study Process.~~

(B) Voltage and power quality screen.

- (i) In aggregate with existing DER on the circuit and line section(s), the voltage regulation on the circuit and line section(s) shall be maintained in compliance with relevant requirements under all system conditions:

- (ii) In aggregate with existing DER on the circuit and line section(s), the voltage fluctuation shall be within acceptable limits as defined by IEEE Standard 1453 and, by utility practice conforming with IEEE Standard 1453, and by the limits defined by IEEE standard 1547; and
 - (iii) In aggregate with existing DER on the circuit and line section(s), the harmonic levels shall meet IEEE Standard 519 limits.
- (C) Safety and reliability screen.
- (i) The location of the proposed DER and the aggregate DER capacity on the line section(s) shall not create impacts to safety or reliability that cannot be adequately addressed without application of the Level 3 process.
 - (ii) Minimum load, minimum loading and minimum load data shall be specific to time(s) of DER production.
 - (iii) The utility shall consider whether the line section(s) has significant minimum loading levels dominated by a small number of customers (e.g., several large commercial customers).
 - (iv) The utility shall consider whether the loading along the line section(s) is uniform or even given the sources of the screening data.
 - (v) The utility shall consider whether the proposed DER is located in close proximity to a substation (i.e., less than 2.5 electrical circuit miles) and whether the line section(s) from the substation to the point of interconnection is a mainline rated for normal and emergency ampacity.
 - (vi) The utility shall consider whether the proposed DER incorporates a time delay function to prevent reconnection of the DER to the utility's system until system voltage and frequency are within normal limits for a prescribed time.
 - (vii) The utility shall consider whether operational flexibility is reduced by the proposed DER, such that transfer of the line section(s) of the DER to a neighboring distribution circuit/substation may trigger overloads or voltage issues.
 - (viii) The utility shall consider whether the proposed DER employs equipment or systems certified by a recognized standards organization to address technical issues such as, but not limited to, islanding, reverse power flow, and voltage quality.
- (VII) If the supplemental screening meets utility determined adequacy with minor modifications, the utility shall provide a non-binding good faith estimate of the limited cost to make such modifications to the utility's electric system upon notification of review results.

(e) Interconnection agreements.

- (I) If the proposed interconnection passes the screens, the interconnection request shall be approved and the utility will provide the IC an executable interconnection agreement within five business days after the determination.
- (II) If the proposed interconnection fails the screens, but the utility determines that the small generating facility may nevertheless be interconnected consistent with safety, reliability, and power quality standards, the utility shall provide the IC an executable interconnection agreement within five business days after the determination.
- (III) If the interconnection customer agrees to pay for the modifications to the utility's electric system as identified by the utility pursuant to subparagraph 3855(c)(II)(A), the utility will provide the interconnection customer with an executable interconnection agreement within ten business days of the customer options meeting.
- (IV) If the interconnection customer agrees to pay for the modifications to the utility's electric system as identified by the utility pursuant to subparagraph 3855(d)(VII), the utility will provide the interconnection customer with an executable interconnection agreement within five business days of IC agreement to pay.

3856. Level 3 Process (Study Process).

Applicability.—This The study process shall be used by an interconnection customer proposing to interconnect its small generating facility-DER with the utility's system if the small generating facility-DER is larger than two MW but no larger than ten-20 MW; is not certified; or, is certified but did not pass the Fast Track Process or the ten kW Inverter Level 1 process or Level 2 Process process.

(a) Scoping meeting.

- (I) A scoping meeting will be held within ten business days after the interconnection request is deemed complete, or as otherwise mutually agreed to by the parties. The utility and the interconnection customer will bring to the meeting personnel, including system engineers and other resources as may be reasonably required to accomplish the purpose of the meeting.
- (II) The purpose of the scoping meeting is to discuss the interconnection request. The parties shall further discuss whether the utility should perform a feasibility study or proceed directly to a system impact study, or a facilities study, or an interconnection agreement. If the parties agree that a feasibility study should be performed, the utility shall provide the IC, as soon as possible, but not later than five business days after the scoping meeting, a feasibility study agreement including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study.
- (III) The scoping meeting may be omitted by mutual agreement. In order to remain in consideration for interconnection, an IC who has requested a feasibility study must return the executed feasibility study agreement within 15 business days. If the parties agree not to perform a feasibility study, the utility shall provide the IC, no later than five business days after the scoping meeting, a system impact study agreement including an outline of

the scope of the study and a non-binding good faith estimate of the cost to perform the study.

- (IV) Feasibility studies, scoping studies, and facility studies may be combined or waived for simpler projects by mutual agreement of the utility and the ~~parties~~IC. If all such studies are waived, the utility shall provide the IC an executable interconnection agreement within ten business days after the scoping meeting. If the scoping meeting is also omitted by mutual agreement, the utility shall provide the IC an executable interconnection agreement within ten business days after the interconnection request is deemed complete and this Level 2 process is completed.

(b) Feasibility study.

- (I) The feasibility study shall identify any potential adverse system impacts that would result from the interconnection of the ~~small generating facility~~DER. At its discretion, the utility may use the Level 2 supplemental review as described in paragraph 3855(d) as the feasibility study.
- (II) A deposit of the lesser of 50 percent of the good faith estimated feasibility study costs or earnest money of \$1,000 may be required from the interconnection customer.
- (III) The scope of and cost responsibilities for the feasibility study are described in the ~~attached~~ feasibility study agreement.
- (IV) If the feasibility study shows no potential for adverse system impacts, the utility shall send the Interconnection Customer a facilities study agreement, including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study.
- (V) If the feasibility study shows the potential for adverse system impacts, the review process shall proceed to the appropriate system impact study(s).
- (VI) If no system impact study is required and no facilities study is required for the DER, the utility shall provide the IC an executable interconnection agreement within five business days after the completion of the feasibility study.

(c) System impact study.

- (I) A system impact study shall identify and detail the electric system impacts that would result if the proposed ~~small generating facility~~DER were interconnected without project modifications or electric system modifications, focusing on the adverse system impacts identified in the feasibility study, or to study potential impacts, including but not limited to those identified in the scoping meeting. A system impact study shall evaluate the impact of the proposed interconnection on the reliability of the electric system.
- (II) If no transmission system impact study is required, but potential electric power distribution system adverse system impacts are identified in the scoping meeting or shown in the feasibility study, a distribution system impact study must be performed. The utility shall send the IC a distribution system impact study agreement within 15 business days of transmittal of the feasibility study report, including an outline of the scope of the

study and a non-binding good faith estimate of the cost to perform the study, or following the scoping meeting if no feasibility study is to be performed.

- (III) In instances where the feasibility study or the distribution system impact study shows potential for ~~transmission system~~ adverse ~~system~~ impacts on the utility's transmission system, within five business days following transmittal of the feasibility study report, the utility shall send the IC a transmission system impact study agreement, including an outline of the transmission-supplied scope of the study and a transmission-supplied non-binding good faith estimate of the cost to perform the study, if such a study is required.
 - (IV) If a transmission system impact study is not required, but electric power distribution system adverse system impacts are shown by the feasibility study to be possible and no distribution system impact study has been conducted, the utility shall send the IC a distribution system impact study agreement.
 - (V) If the feasibility study shows no potential for transmission system or distribution system adverse system impacts, the utility shall send the IC either a facilities study agreement, including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the study, or an executable interconnection agreement, as applicable.
 - (VI) In order to remain under consideration for interconnection, the IC must return executed system impact study agreements, if applicable, within 30 business days.
 - (VII) A deposit of the good faith estimated costs for each system impact study may be required from the IC.
 - (VIII) The scope of and cost responsibilities for a system impact study are described in the system impact study agreement.
 - (IX) Where transmission systems and distribution systems have separate owners, such as is the case with transmission-dependent utilities (TDUs) – whether investor-owned or not – the IC may apply to the nearest utility (Transmission Owner, Regional Transmission Operator, or Independent utility) providing transmission service to the TDU to request project coordination. Affected systems shall participate in the study and provide all information necessary to prepare the study.
 - (X) If no facilities study is required for the DER, the utility shall provide the IC an executable interconnection agreement within five business days after the completion of the system impact study.
- (d) Facilities study.
- (I) Once the required system impact study(s) is completed, a system impact study report shall be prepared and transmitted to the IC along with a facilities study agreement within five business days, including an outline of the scope of the study and a non-binding good faith estimate of the cost to perform the facilities study. In the case where one or both impact studies are determined to be unnecessary, a notice of the fact shall be transmitted to the IC within the same timeframe.

- (II) In order to remain under consideration for interconnection, or, as appropriate, in the utility's interconnection queue, the IC must return the executed facilities study agreement or a request for an extension of time within 30 business days.
- (III) The facilities study shall specify and estimate the cost of the equipment, engineering, procurement, and construction work (including overheads) needed to implement the conclusions of the system impact study(s).
- (IV) Design for any required interconnection facilities and/or upgrades shall be performed under the facilities study agreement. The utility may contract with consultants to perform activities required under the facilities study agreement. The IC and the utility may agree to allow the IC to separately arrange for the design of some of the interconnection facilities. In such cases, facilities design will be reviewed and/or modified prior to acceptance by the utility, under the provisions of the facilities study agreement. If the parties agree to separately arrange for design and construction, and provided security and confidentiality requirements can be met, the utility shall make sufficient information available to the IC in accordance with confidentiality and critical infrastructure requirements to permit the IC to obtain an independent design and cost estimate for any necessary facilities.
- (V) A deposit of the good faith estimated costs for the facilities study may be required from the IC.
- (VI) The scope of and cost responsibilities for the facilities study are described in a facilities study agreement.
- (VII) Upon completion of the facilities study, and with the agreement of the IC to pay for interconnection facilities and upgrades identified in the facilities study, the utility shall provide the IC an executable interconnection agreement within five business days.

3857. Certification Codes and Standards.

ANSI C84.1-~~2011~~2016 Electric Power Systems and Equipment – Voltage Ratings (60 Hertz)

ANSI/NEMA MG 1--~~2011~~2016, Motors and Generators

IEEE Std C37.90.1-~~2002~~2012, IEEE Standard Surge Withstand Capability (SWC) Tests for Protective Relays and Relay Systems

IEEE Std C37.90.2-2004, IEEE Standard Withstand Capability of Relay Systems to Radiated Electromagnetic Interference from Transceivers

IEEE Std C37.108-2002, IEEE Guide for the Protection of Network Transformers

IEEE Std C57.12.44-~~2005~~2014, IEEE Standard Requirements for Secondary Network Protectors

IEEE Std C62.41.2-2002/Cor 1-2012, IEEE Recommended Practice on Characterization of Surges in Low Voltage (1000V and Less) AC Power Circuits Corrigendum 1: Deletion of Table A.2 and Associated Text

IEEE Std C62.45-2002, IEEE Recommended Practice on Surge Testing for Equipment Connected to Low-Voltage (1000V and Less) AC Power Circuits

IEEE Std 100-2000, The Authoritative Dictionary of IEEE Standards Terms, Seventh Edition

IEEE Std 519-2014, IEEE Recommended Practices and Requirements for Harmonic Control in Electrical Power Systems

~~IEEE Std 929-2000 IEEE Recommended Practice for Utility Interface of Photovoltaic (PV) Systems~~

~~IEEE Std 1453-2015 IEEE Recommended Practice for the Analysis of Fluctuating Installation on Power Systems~~

IEEE Std 1547-~~2003~~2018, IEEE Standard for Interconnection and Interoperability of Interconnecting Distributed Energy Resources with Associated Electric Power Systems Interfaces

IEEE Std 1547.1-2005, IEEE Standard Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems

NFPA 70 (~~2014~~2017), National Electrical Code

UL 1741 Inverters, Converters, and Controllers for Use in Independent Power Systems

3858. Certification of ~~Small Generator-DER~~ Packages.

- (a) Small generating facility equipment proposed for use separately or packaged with other equipment in an interconnection system shall be considered certified for interconnected operation if it has been tested in accordance with industry standards for continuous utility interactive operation in compliance with the appropriate codes and standards referenced below by any Nationally Recognized Testing Laboratory (NRTL) recognized by the United States Occupational Safety and Health Administration to test and certify interconnection equipment pursuant to the relevant codes and standards listed in paragraph (h); it has been labeled and is publicly listed by such NRTL at the time of the interconnection application; and, such NRTL makes readily available for verification all test standards and procedures it utilized in performing such equipment certification, and, with consumer approval, the test data itself. The NRTL may make such information available on its website and by encouraging such information to be included in the manufacturer's literature accompanying the equipment.
- (b) The interconnection customer must verify that the intended use of the equipment falls within the use or uses for which the equipment was tested, labeled, and listed by the NRTL.
- (c) Certified equipment shall not require further type-test review, testing, or additional equipment to meet the requirements of this interconnection procedure; however, nothing herein shall preclude the need for an on-site commissioning test by the parties to the interconnection nor follow-up production testing by the NRTL.
- (d) If the certified equipment package includes only interface components (switchgear, inverters, or other interface devices), then an Interconnection Customer must show that the generator or other

electric source being utilized with the equipment package is compatible with the equipment package and is consistent with the testing and listing specified for this type of interconnection equipment.

- (e) Provided the generator or electric source, when combined with the equipment package, is within the range of capabilities for which it was tested by the NRTL, and does not violate the interface components' labeling and listing performed by the NRTL, no further design review, testing or additional equipment on the customer side of the point of ~~common-coupling~~interconnectoin shall be required to meet the requirements of this interconnection procedure.
- (f) An equipment package does not include equipment provided by the utility.

3859. – 3874. [Reserved].